

(xxi) The construction of the structure or pandal shall be such as to accommodate independently any stand by fire engines from department of fire service.

(xxii) There shall be not less than four exit gates on the boundary wall at a distance of 250 feet from each other.

(xxii) Private security staff employed in the pandal, the organizers and the stall holders shall know how to operate the first aid fire extinguishers to kill the fire at its initial stage.

(xxiii) The Director or any such authorized officer may impose any further conditions which deemed suitable as situation demands and the organizer shall be bound to abide by the same.
